



**Indiana Department of Labor and CCS
Monthly Partnership Report
June 2025**

The following companies are signatory to the IDOL/CCS Partnership Agreement:

AAA Roofing Co., Inc.	ERMCO
Advanced Rescue Solutions	F.A. Wilhelm Construction Co., Inc.
AECOM Hunt	F.E. Moran, Inc. Fire Protection
Airtek Construction	F.E. Moran, Inc. Special Hazard Systems
Allison Farms Lawn & Landscaping	Freitag-Weinhardt, Inc.
ASI	Gaylor Electric, Inc.
BMWC Constructors	Georgia Western, LLC
Blood Hound, LLC	Gibson-Lewis of Indianapolis, LLC
Bowen Engineering Corporation	Gribbins Insulation Co., Inc.
Brehob Corporation	Harrell-Fish, Inc.
Broady-Campbell	Henry C. Smither Roofing Co., Inc.
Brown Sprinkler Corporation	Hoist & Crane Service Group
C&C Sheet Metal, LLC	Horning Roofing & Sheet Metal Co. LLC
Cathodic Protection Management	Industrial Electric, Inc.
Charah, LLC	Interior Specialties
CMS Corporation	JDH Contracting
D.A. Dodd, LLC	J.F. Electric, Incorporated
Denney Excavating, Inc.	JMH Roofing Co., Inc.
Diversified Painting Co.	JT Thorpe & Son, Inc.
Edwards Electrical & Mechanical	Johnson Controls
*Electric Plus, Inc.	Keramida
Empire Contractors	Kirk Erectors
Engineered Facades	Kleis Construction

Leach & Russell Mechanical

Long Electric Co. Inc.

Lytle Electric

Mason Private Locating

Meade, Inc.

Mel-Kay Electric

Messer Construction Co.

Millennium Steel Inc.

Miller-Eads Co. Inc.

M.J. Electric, IPC

N.M. Bunge, Inc.

Performance Contracting Inc.

Poettker Construction Company

Poynter Sheet Metal

PPMI Firestop

Premier Power Maintenance

R. Adams Roofing

Ragle, Inc.

Reliance Engineering

Richeson Cabinets

Ritter Plbg Co Inc.

River Town Construction, LLC

RLTurner

RSQ Fire Protection

Ryan Fireprotection, Inc.

Safety Medic

Santarossa Mosaic & Tile Co., Inc.

Scaffold King Rentals, Inc.

Shambaugh & Son L.P.

- **Dalmation Fire**

- **Ed Grace**

- **Havel**

- **ASG**

- **AS/CC**

Shiel Sexton Company, Inc.

Smock Fansler Corporation

Smoot Construction, LLC

Solid Platforms, Inc.

STAR Environmental

***STATS International, Inc.**

Steinberger Construction

Sterling Industrial, LLC

Sub-Surface of Indiana, Inc.

Sullivan & Poore, Inc.

Summit Construction Co., Inc.

Superheat FGH Services

The Blakley Corporation

- **Gates Company**

- **AWS**

- **Ceramic Tile and Terrazzo**

The Skillman Corporation

The State Group Industrial (USA)

Tonn and Blank

Triangle Enterprises, Inc.

***Turner Construction Company**

US Hydrovac Inc.

Wealing Brothers

Weddle Bros. Construction Companies

Wright Tree Service

June RATES

Aggregate Partnership Days Away Restricted and Transfer (DART) Rate: 0.23

Total Number of OSHA Cases with Days Away, Restriction or Transfer X 200,000

7

Total Number of Hours Worked by Partners

6,011,663

Aggregate Partnership Total Recordable Case (TRC) Rate: 0.73

Total Number of OSHA Recordable Incidents X 200,000

22

Total Number of Hours Worked by Partners

6,011,663

YTD RATES

Aggregate Partnership Days Away Restricted and Transfer (DART) Rate: 0.15

Total Number of OSHA Cases with Days Away, Restriction or Transfer X 200,000

30

Total Number of Hours Worked by Partners

39,057,004

Aggregate Partnership Total Recordable Case (TRC) Rate: 0.51

Total Number of OSHA Recordable Incidents X 200,000

99

Total Number of Hours Worked by Partners

39,057,004

Incident Number	Date	Incident Narrative
1	6/2025	(H) A scaffold board fell, striking an employee below, causing a laceration to the employee's forearm.
2	6/2025	(H) While replacing a 125-amp fuse, an ARC flash occurred, resulting in electrical burns to both of the employee's arms.
3	6/2025	(H) Employee removed a cover off of a section of a switch gear and attempted to check phase rotation. The meter that he was using was a dual-purpose meter. Employee used the meter incorrectly and the meter blew up. This caused an Arc fault on the gear. Employee suffered burns to his forehead and both hands. The employee had FR clothing on but did not put on FR face shield or hand protection.
4	6/2025	(I) While cutting copper pipe to install an angle valve under a sink, the blade of the saw got bound up and the employee's hand slipped, resulting in a finger laceration needing stitches.
5	6/2025	(I) Employee bent over to grab material, stood up, and hit his head on an AC Unit, resulting in a head laceration needing stitches.
6	6/2025	(I) Employee pinched their finger between a wrench and a tank head while adjusting the gear box and plate bolts, resulting in a tuft fracture of their left pinky finger.
7	6/2025	(I) Employee was taking jugs of refrigerant up a ladder and felt his knee pop, resulting in knee inflammation.
8	6/2025	(J) Employee was performing camera sewer work inside of a building when he began to feel pain in his lower back. Employee had a sprain/strain, needing anti-inflammatory medication.
9	6/2025	(J) Employee fell from a height, fracturing two ribs.
10	6/2025	(J) Employee was rolling a duct and did not have the correct PPE on. He lacerated his right palm, needing stitches.
11	6/2025	(J) Employee was cutting material with a knife and cut their leg after cutting through the material. This laceration to their lower leg required stitches.
12	6/2025	(J) While cutting a ¾ inch conduit with a reciprocating saw, the cut a piece of conduit unexpectedly fell, cutting the employee's right arm.
13	6/2025	(J) Employee was retrieving material from a Knack box when he let go of the lid. The lid was not locked open, so it fell on his right index finger causing a fracture.
14	6/2025	(J) Employee tore their left bicep when lifting something.
15	6/2025	(J) Employee was walking over an unsecured pick board and the board shifted. Employee lost his balance, fell onto the level below, and cut his arm, needing stitches.
16	6/2025	(J) A bar clamp was standing on its end against a rack in a welding station. It fell over and struck the employee in the head, resulting in the employee receiving stitches.
17	6/2025	(J) Employee was helping load fabrications onto a trailer and the pipe bullhorn was hit by the load, causing it to fall and strike the employee's hand. Employee needed stitches.
18	6/2025	(J) Employee backed a drill out of a hole and dust blew into his eyes, resulting in him getting his eyes flushed.
19	6/2025	(J) Employee was going to grab material and as he turned, his foot slipped on mud/water and he fell on his elbow, breaking his humerus needing a cast.
20	6/2025	(J) Employee was laying out the electrical rough in the training room. While laying out this room, the employee saw two pieces of scrap drywall in his way. He picked up the two pieces of drywall to move to another wall and his right index finger hit the metal X bracing on the framing. This caused a laceration across the second knuckle of his right index finger. The employee was taken to the local urgent care for treatment and received 3 stitches.
21	6/2025	(J) Employee was conducting a pneumatic pressure test and had air infiltration to his left hand through his gloves.

22	6/2025	(J) Employee received a corneal abrasion due to debris getting into their eye.
----	--------	--------------------------------------------------------------------------------

*Companies on probation for not reporting statistics for June: Electric Plus, Inc. STATS International Turner Construction Company	**Companies Suspended due to Not Current Status:
Companies removed from partnership:	Companies added to partnership: